



COMPLIANCE

with IEC EN 61508 and IEC EN 61511

Certificate No.: C-IS-722144112-01

CERTIFICATE OWNER: Valpres S.r.l.
Via Gitti 11
25060 Marcheno V.T. (BS) - Italy

**WE HEREWITH CONFIRM THAT
 THE BALL VALVES
 MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLE
 FOR THE SAFETY FUNCTION:**

“correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation”
“correct switching on demand (closed to open), in low demand mode of operation”

Examination result: The above reported Ball Valves were found to meet the standard defined requirements of the safety levels detailed in the following table (T-IS-722144112-01) according to IEC EN 61508 and IEC EN 61511, under fulfillment of the conditions listed in the Report R-IS-722144112-01 Rev.1 dated September, 14th 2017 in its currently valid version, on which this Certificate is based

Examination parameters: Construction/Functional characteristics and reliability and availability parameters of the above mentioned Ball Valves

Official Report No.: R-IS-722144112-01 Rev.1

Expiry Date September, 13th 2020

IT IS TO BE INTENDED THAT THE ABOVE OFFICIAL REPORT AND ITS ANNEXES ARE AN INTEGRAL PART OF THIS DOCUMENT
 THE PRESENT DOCUMENT SUBSTITUTES AND REPEALS THE DOCUMENTS C-IS-250138-01

Reference Standard IEC EN 61508:2010 Part 2, 4, 6, 7 - IEC EN 61511:2016 Part 1, 2, 3

Sesto San Giovanni, September, 14th 2017

TÜV ITALIA Srl

TÜV ITALIA Srl
Industry Service Division
Director



Paolo Marccone



Italia

SUMMARY TABLE T – IS – 722144112 – 01

<i>E/EE/EP safety-related system (final element)</i>	Ball Valves produced by Valpres S.r.l.	
<i>System type</i>	Type A	
<i>Class</i>	Ball Valve series 76 - gasket PTFE (Class 1)	Ball Valve series 76 - gasket PTFE + glass (Class 2)
<i>Systematic Capability</i>	SC3	
<i>Safety Function Definition</i>	<i>SIF1: Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation¹</i>	
<i>Max SIL⁽¹⁾</i>	SIL 3	SIL 3
λ_{TOT}	1,065E-08	2,547E-08
λ_{NE}	2,911E-09	2,417E-09
λ_S	0,000E+00	0,000E+00
$\lambda_{DD,PST}^{(2)}$	5,821E-10	8,175E-10
$\lambda_{DU,FP1}$	7,162E-09	2,223E-08
<i>β and β_D factor</i>	10%	10%
<i>MTTR</i>	8 h	8 h
<i>Hardware Safety Integrity</i>	Route 2 _H	Route 2 _H
<i>Systematic Safety Integrity</i>	Route 2 _S	Route 2 _S
<p>Remarks</p> <p>(1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{avg} considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.</p> <p>(2) Considering an automatic Partial Stroke Testing</p>		

SIL classification according to Standards IEC EN 61508:2010 and IEC EN 61511:2016 for the Ball Valves produced by Valpres S.r.l. – SIF1



T – IS – 722144112 – 01

NOTE: The present table is integral part of the Documents: from C-IS-722144112-01

Date: September, 14th 2017

<i>E/EE/EP safety-related system (final element)</i>	Ball Valves produced by Valpres S.r.l.	
<i>System type</i>	Type A	
<i>Class</i>	Ball Valve series 76 - gasket PTFE (Class 1)	Ball Valve series 76 - gasket PTFE + glass (Class 2)
<i>Systematic Capability</i>	SC3	
<i>Safety Function Definition</i>	<i>SIF2: Correct switching on demand (closed to open), in low demand mode of operation</i> ¹¹	
<i>Max SIL⁽¹⁾</i>	SIL 3	SIL 3
λ_{TOT}	1,065E-08	2,547E-08
λ_{NE}	7,572E-09	1,133E-08
λ_S	0,000E+00	0,000E+00
$\lambda_{DD,PST}$ ⁽²⁾	1,013E-09	2,422E-09
$\lambda_{DU,FFT}$	2,070E-09	1,172E-08
<i>β and β_D factor</i>	10%	10%
<i>MTTR</i>	8 h	8 h
<i>Hardware Safety Integrity</i>	Route 2 _H	Route 2 _H
<i>Systematic Safety Integrity</i>	Route 2 _S	Route 2 _S
<p>Remarks (1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{AVG} considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements. (2) Considering an automatic Partial Stroke Testing</p>		

SIL classification according to Standards IEC EN 61508:2010 and IEC EN 61511:2016 for the Ball Valves produced by Valpres S.r.l. – SIF2



T – IS – 722144112 – 01

NOTE: The present table is integral part of the Documents: from C-IS-722144112-01

Date: September, 14th 2017